

PROJECT OUTCOME CERTIFICATE

Name of the Project	Laying of pipe line in different lanes including slums of different wards of Angul Municipality for Improvement of water supply.		
Project Code			
Project Components (to be filled by the PHED)			
Intake (dia. & Cap. In MLD)	-		
WTP (Cap. in MLD)	-		
Production Well (Nos. & Cap. In ML)	-		
Storage ESR (Nos. & Cap. In ML) GSR (Nos. & Cap. In ML)	-		
Distribution network (length in km)	200 mm diameter D.I pipe = 0.495 150 mm diameter D.I pipe = 3.32 100 mm diameter D.I pipe = 0.88		
Outcome (Pre & Past target to be entered by PHEO in sync. With monitoring tool)			
Description	Pre Implementation	Post Implementation Target	Post Implementation Actual (to be verified & recorded by the team)
Increase in Supply Quantity (LPCd*)	-	100	100
Storage (ML)	-	-	-
Increase in Supply Duration (Hrs)	-	-	-
Household Coverage in Project area	House Hold = 253 Nos House Connection = 181 Nos	72	60
Equity & Adequacy Adequate quantity reaches last house in tail end)	Yes	<input checked="" type="checkbox"/>	Yes
	No	-	Yes
*Computation of LPCD= (Daily quantity supplied to project area in ltr)/(total population in project area)			

Certified that the above project has been completed and put to service. The information provided herein are correct to best of our knowledge.

Signature, Name & Designation

<p><i>Samita Kar</i> 14.9.18</p> <p>SAMITA KAR</p>	<p><i>[Signature]</i> 14.9.18</p> <p>Executive Officer Angul Municipality</p>	<p><i>[Signature]</i> 28/9/18</p> <p>Sub-Collector Angul</p>	<p><i>[Signature]</i> 14.9.18</p> <p>Assistant Engineer P.H. Section, Angul PHEO Representative</p>
Councillor (s) Councillor Ward No-07 Corporator (s) Angul Municipality	Commissioner's/Executive Officer's representative	Collector's Representative	PHEO Representative

Note: This certification cannot be treated as confirmation or approval of execution quantity.