





## PROJECT OUTCOME CERTIFICATE


Name of the Project	Replacement of smaller diameter pipe line in Hindol Sahi (Ward No. 4 & 11) and Rugudi Sahi (Ward No. 5) at Athamallik under State Action Plan 2017-18.		
Project Code	1506427364732		
<b>Project Components</b> (to be filled by the PHED)			
Intake (dia. & Cap. In MLD)			
WTP (Cap. in MLD)			
Production Well (Nos. & Cap. In ML)			
Storage ESR (Nos. & Cap. In ML)			
GSR (Nos. & Cap. In ML)			
Distribution network (length in km)	200 mm diameter D.I Pipe = 0.495 Km. 150 mm diameter D.I Pipe = 0.170 Km. 100 mm diameter D.I Pipe = 0.796 Km. Total = 1.461Km		
<b>Outcome</b> (Pre & Post target to be entered by PHEO in sync. With monitoring tool)			
Description	Pre Implementation	Post Implementation Target	Post Implementation Actual (to be verified & recorded by the team)
Increase in Supply Quantity (LPCd*)	-	-	-
Storage (ML)	-	-	-
Increase in Supply Duration (Hrs)	2 hrs	2 hrs	2 hrs
Household Coverage in Project area	House Hold = 142 Nos. House Connection = 105 Nos	37 Nos.	6 Nos.
Equity & Adequacy Adequate quantity reaches last house in tail end)		Yes	✓
		No	
*Computation of LPCD= (Daily quantity supplied to project area in ltr)/(total population in project area)			

Certified that the above project has been completed and put to service. The information provided herein are correct to best of our knowledge.

**Signature, Name & Designation**

 Councillor ward No-11 Athamallik N.A.C.	 Commissioner's/Executive Officer's representative Athamallik	 Sub - Collector Athamallik.	 Junior Engineer PHEO Representative P.H. Section, Athamallik.
Councillor (s)/ Corporator (s)	Commissioner's/Executive Officer's representative	Collector's Representative	Junior Engineer PHEO Representative P.H. Section, Athamallik.

Note: This certification cannot be treated as confirmation or approval of execution quantity.

  
 Councillor  
 ward No-5  
 Athamallik N.A.C.