

### PROJECT OUTCOME CERTIFICATE

Name of Project	Sinking of 200mm dia production well at Jamuhota for improvement of water supply to Ward No. 11 & 12 of Keonjhar Municipality.
Project code	
<b>Project components</b> <i>(to be filled in by PHEO)</i>	
Intake ( dia. & Cap. in MLD)	
WTP (Cap. in MLD)	
Production well (Nos. & Cap. in ML)	200mm Dia Production well (0.02MLD) Total - 1 No.
Storage ESR (Nos. & Cap. in ML) GSR (Nos. & Cap. in ML)	
Distribution network (length in Km)	

#### Outcome

*(Pre & post target to be entered by PHEO in sync. with monitoring tool)*

Description	Pre Implementation	Post Implementation Target	Post Implementation -Actual (to be verified & recorded by the team)
Increase in Supply Quantity (LPCD*)	62 LPCD	82 LPCD	
Storage (ML)	-	-	
Increase in Supply Duration (Hrs)	4 Hrs	4 Hrs	
Household Coverage In project area	Total Household- 45 & connection 45 Nos.		
Equity & Adequacy <i>(Adequate quantity reaches last house in tail end)</i>	Yes	<input checked="" type="checkbox"/>	<i>Please Tick the appropriate box</i>
	No	<input type="checkbox"/>	
<i>*Computation of LPCD =(Daily quantity supplied to project area in ltr)/(total population in project area)</i>			

Certified that the above project has been completed and put to service. The information provided herein are correct to best of our knowledge.

#### Signature, Name & Designation

1) <i>Fareeh Sahasrab Singh</i> W.No-11 2) <i>Satyaprava Sethu</i>	 <b>Municipal Engineer</b> Keonjhar Municipality	 <b>Collector's Representative</b> KEONJHAR	 <b>Assistant Executive Engineer</b> PHEO P.H. Sub-Division, Keonjhar
--	---	---	---

Note: This certification cannot be treated as confirmation or approval of execution quantity