

PROJECT OUTCOME CERTIFICATE

Name of Project	"Sinking of Production well at Kucheiburi for Improvement of Water Supply to scarcity area of Ward No- 03,04 & 15 of Rairangpur Municipality".
Project code	
Project components (to be filled in by PHEO)	
Intake (dia & Cap. In MLD)	—
WTP (Cap. In MLD)	—
Production well (Nos. & Cap. In ML)	1 No. 0.04 MLD.
Storage ESR (Nos. & Cap. In ML) GSR (Nos. & Cap. In ML)	—
Distribution network (Length in km)	100 mm dia D.I k-7 pipe. 18 mtr.

Outcome (Pre & post target to be entered by PHEO in sync. With monitoring tool)			
Description	Pre Implementation	Post Implementation- Target	Post Implementation- Actual (to be Verified & recorded by the team)
Increase in Supply Quantity (LPCD*)	75 LPCD	85 LPCD	
Storage(ML)	—	—	
Increase in Supply Duration(Hrs)	2 Hrs	3.5 Hrs	
Household coverage in project area 283	(Enter Total no. Of house in the project area & existing connections if any) 209	(Enter Target no. Of New connection) 74 No	(Enter actual no. Of new connections) 42 nos of applications Received. Connectors to be provided.
Equity & Adequacy (Adequate quantity reaches last house in tail end)	Yes	<input checked="" type="checkbox"/>	Please Tick the appropriate box
	No	<input type="checkbox"/>	

*Computation of LPCD = (daily quantity supplied to project area in ltr) / (total population in project area)


Certified that the above project has been completed and put to service. The information provided herein are correct to best of our knowledge.

Signature, Name & Designation

Councillor(s)/ Corporator (s)	Executive Officer's representative	Collector's Representative	PHEO Representative

Note: This certification cannot be treated as confirmation or approval of execution quantity.

Sarathi Mm.
25.5.18


 Ansuman Puri
 Junior Engineer TL, DUDA
 Rairangpur Municipality. 25/5/18


 Assistant Engineer
 P.H. Section, Rairangpur