





PROJECT OUTCOME CERTIFICATE

Name of the Project	Water Supply to Sidhapur and Fakir Pada village of ward No. 3 of Athamaliik NAC under DMF Fund.		
Project Code			
Project Components (to be filled by the PHED)			
Intake (dia. & Cap. In MLD)			
WTP (Cap. in MLD)			
Production Well (Nos. & Cap. In ML)			
Storage ESR (Nos. & Cap. In ML) GSR (Nos. & Cap. In ML)	0.90 lakh litre OGR- 1 No.		
Distribution network (length in km)	160 mm diameter (6 kgf/cm ²) PVC Pipe = 3.99 Km. 110 mm diameter (6 kgf/cm ²) PVC Pipe = 2.24 Km. Total = 6.23 Km		
Outcome (Pre & Past target to be entered by PHEO in sync. With monitoring tool)			
Description	Pre Implementation	Post Implementation Target	Post Implementation Actual (to be verified & recorded by the team)
Increase in Supply Quantity (LPCd*)	-	135	135
Storage (ML)	-	0.09	0.09
Increase in Supply Duration (Hrs)	-	1 hr	1 hr
Household Coverage in Project area	House Hold = 75 Nos. House Connection = Nil	75	25
Equity & Adequacy Adequate quantity reaches last house in tail end)		Yes	
		No	
*Computation of LPCD= (Daily quantity supplied to project area in ltr)/(total population in project area)			

Certified that the above project has been completed and put to service. The information provided herein are correct to best of our knowledge.

Signature, Name & Designation

 Councillor (s) Corporator (s)	 Commissioner's/Executive Officer's representative Athamaliik	 Collector Athamaliik	 Junior Engineer P. M. G. G. Athamaliik
---	---	---	--

Note: This certification cannot be treated as confirmation or approval of execution quantity.