




PROJECT OUTCOME CERTIFICATE

Name of the Project	Water supply to Rajkishorepada and adjoining areas (W. No. 1,2,18 & 19) of Angul Municipality under State Action Plan 2017-18.		
Project Code			
Project Components (to be filled by the PHED)			
Intake (dia. & Cap. In MLD)	-		
WTP (Cap. in MLD)	-		
Production Well (Nos. & Cap. In ML)	-		
Storage ESR (Nos. & Cap. In ML) GSR (Nos. & Cap. In ML)	1. ESR 0.2 ML, 25 mtr. staging = 1 No. 2. OGR 0.3 ML = 1 No.		
Distribution network (length in km)	1. 200 mm dia D.I pipe = 1.20 K.M 2. 150 mm dia D.I pipe = 3.87 K.M 3. 100 mm dia D.I pipe = 4.03 K.M 4. 200 mm dia M.S Pipe = 0.16 K.M 5. 150 mm dia M.S pipe = 0.28 K.M 6. 100 mm dia M.S pipe = 0.265 K.M Total = 9.80 K.M		
Outcome (Pre & Past target to be entered by PHEO in sync. With monitoring tool)			
Description	Pre Implementation	Post Implementation Target	Post Implementation Actual (to be verified & recorded by the team)
Increase in Supply Quantity (LPCd*)	-	100 LPCD	100 LPCD
Storage (ML)	-	0.5 ML	0.5 ML
Increase in Supply Duration (Hrs)	-	2 hrs	2 hrs
Household Coverage in Project area	House Connection = Nil	252	20
Equity & Adequacy Adequate quantity reaches last house in tail end)		Yes	-
		No	-
			Yes

*Computation of LPCD= (Daily quantity supplied to project area in ltr)/(total population in project area)

Certified that the above project has been completed and put to service. The information provided herein are correct to best of our knowledge.

Signature, Name & Designation

	 Executive Officer Angul Municipality Commissioner's/Executive Officer's representative	 Collector's Representative Sub-Collector Angul	 Assistant Engineer P.H.E. Section, Angul
Councillor (s)/ Corporator (s)			

Note: This certification cannot be treated as confirmation or approval of execution quantity.